

Eco-Sol Ltd
Cardiff House
Cardiff Road
Barry
Vale of Glamorgan
CF63 2AW
United Kingdom



Company Registration No: 06385001
Certificate Reference: SOP-1927
Date Issued: 25 August 2026

Textile Statement of Performance

Flametect Nitro Textile Fire Retardant Treatment

This document confirms that Flametect Nitro fire retardant treatment products supplied under the order referenced below are intended for the treatment of textile materials including curtains, drapes and decorative fabrics.

Customer Information

Customer / Company Joe Bloggs – For Example Purposes only
Address NA, NA, NA, United Kingdom
Order Order No: #1927 | Date: 25 August 2026

Purchase Summary

Total Quantity Purchased 5.0 Litres Certified Coverage Range 35.0 m² – 50.0 m²
Coverage Rate 7–10 m² per litre

Products Supplied

Product	SKU	Qty
Flametect Nitro for Synthetic & Natural Textiles - 5 ltr	FN5	5.0 L

Independent Fire Test Results

Standard	Description	Laboratory	Result
BS 5438	Bottom Edge Ignition	BTTG	Pass
BS 5852	Cigarette & Match Test	HSTTS	Pass*
BS 5867 Pt 2 Type B	Damask Fabric	UKAS Accredited	Pass
BS 5867 Pt 2 Type B	Linen Fabric	UKAS Accredited	Pass
BS 5867 Pt 2 Type B	Polyester Lycra Fabric	UKAS Accredited	Pass
California Title 19	Section 1237 Textile Test	Independent Lab	Pass
BS EN 13773	Heavy Weight Fabric	Independent Lab	Class 1
BS EN 13773	Light Weight Fabric	Independent Lab	Class 1
DIN 4102	Light Weight Fabric	TUM Munich	Pass
DIN 4102	Medium Weight Fabric	TUM Munich	Pass

* BS 5852 Pass achieved. Testing did not include BS 5651 water-soak and conditioning.

Eco-Sol Due Diligence

Eco-Sol Ltd commissions independent fire performance testing through accredited laboratories replicating intended end-use applications.

Users Due Diligence (to be signed after application)

- Materials treated are compatible
- Test results are relevant
- Statement acceptable to authorities
- Product applied according to guidance

User / Applicator to sign below

Signature _____ Date _____

Authorised by
Eco-Sol Ltd Technical Department



Scan to verify certificate

This Statement of Performance confirms the supply of Flametect Nitro fire retardant treatment products referenced above.